



Notes and specifications.

Pitched Roof with LR (Breathable) Underlay.

In accordance with BS 5250:2011 ventilation should be provided to any void which occurs beneath any impermeable layer placed on the cold side of any thermal insulation. Airflow should be provided in the batten space ventilated at both eave & ridge levels.

1. CEDRAL 25mm over fascia vent
2. Counter Battens to S.R. 82:2017, BS 5534:2014 Standard.
3. CEDRAL Copper disc rivets. (See CEDRAL fixing guide)
4. Headlap as per site Exposure (Consult SR82:2017)
5. Slating battens to S.R. 82:2017, BS 5534:2014 Standard.
6. CEDRAL Vented Ridge Roll

All slates to be fixed and counter battens to be installed in accordance with S.R. 82:2017, BS5534:2014, BS8000-6:2013
Applicable to Cedral Thrutone Endurance, Rivendale & Supercem Slates.

For further information, please contact;

Website: www.cedral.world support.ireland@etexgroup.com : Tel: +.353 (059) 8631316.

Etex Ireland Ltd. Kilkenny Road, Athy, R14 VN84.

CEDRAL is independently certified as meeting requirements of ISO 9001 (Quality), ISO 14001 (Environment), ISO 45001 (Safety) and BES 6001 (Responsible Sourcing)

CEDRAL are the only manufacturers of Fibre Cement Slates in Ireland and source all raw materials locally wherever possible